



# Development of Self-Instructional Guide for Installation of Solar Power System for Electrical Craftsmen in Nigeria

Sunday A. Alome, Garba A. Usman, Emmanuel Raymond, Samuel A. Owodunni Industrial and Technology Education Department, Federal University of Technology, Minna, Nigeria

# ABSTRACT

The study developed a self-instructional guide for installation of solar power system for electrical craftsmen in Nigeria. The lack of good installation in solar power industries and lack of reliable and sustainable electricity in Nigeria has made solar power systems a viable option for providing power to households and businesses. However, the installation of solar power systems requires specialized knowledge and skills that are not readily available to electrical craftsmen in Nigeria. The development of a self-instructional guide provided solution to this challenge by equipping electrical craftsmen with the necessary knowledge and skills to install and maintain solar power systems. The guide was developed through a review of existing literature and consultations with Subject Matter Experts (SMEs) in the field of solar power systems. The guide was designed to be userfriendly and included detailed step-by-step instructions, diagrams, and illustrations. The effectiveness of the selfinstructional guide was evaluated through a field study involving electrical craftsmen in Nigeria. The results of the study provided insights into the usefulness of the guide and its potential impact on the adoption of solar power systems in Nigeria.

#### **INTRODUCTION**

Solar Power System (SPS) is a form of photoelectric process of converting solar energy directly to electrical energy. According to Dahuwa *et al*, (2017) SPS is the process which sunlight is converted in to electricity through a photocell, this could be in a stand-alone home system or industrial layout fashion. It includes a Photovoltaic (PV) module, charge controller, inverter, battery, solar tracker, combiner box, fuse, and interconnection cable installed as a unit to produce direct or alternating current (Messenger, 2017). Solar power

# ARTICLE INFO

Article History Received: November, 2022 Received in revised form: January, 2023 Accepted: March, 2023 Published online: May, 2023

# **KEYWORDS**

Self -instructional guide, Installation, Solar power system, Electrical craftsmen.

system derived directly or indirectly as an effect of the "sun's energy" is classified as Renewable Energy (RE) and is renewed indefinitely by nature. SPS is sustainable, it can be replenished, and has no harmful side effects for the most part of climate change, majorly caused by environmental pollution (e.g., carbon emission), it has been the main trigger for actions taken by most world governing bodies towards the employment of these renewable (alternative) energy resources. SPS is very reliable and clean source of electricity that can suit wide range of application such as residence,

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved



IOURNAL OF SCIENCE TECHNOLOGY AND EDUCATION 11(1), MARCH, 2023 ISSN: 2277-0011; Journal homepage: www.atbuftejoste.net



industry, agriculture and others but Mughees *et al*, (2020) noted that solar power system installed face degradation of efficiency due to shading, temperature rise and dust accumulation as a result of improper installation.

Installation is a combination of electrical equipment arranged from electrical supply to fulfil a particular purpose. Ihediwah, (2017) defined installation as the coordinated activities carried on a piece of equipment or machines in a systematic manner to make it active for use. Despite the potentials of SPS, the number of solar energy projects in Nigeria are still minimal because of several installation issues that really require much attention (Mutezo and Mulopo, 2021). Some of these issues are listed thus: wrong selection of panels (Mono or Poly) placement of panels at very wrong degrees, poor understanding of the consumption rate, under sizing of system, poor designing, wrong cabling and incompetent installers (Zhang et al, 2021). Ukandu, (2016) further stated that there are many factors that limit installation of solar power system. These are determination of weather condition, location, load factor, complicated wire tie-ins, battery wiring, solar cells positioning, roof placement installation, and electrical panel connections. The fragile nature of the SPS requires experts the components since proper on installation is an activity that help prolong the life of the SPS, it is an activity that require professionals with reasonable level of expertise like electrical craftsmen.

Electrical craftsmen are individuals who have undergone training in any electrical trade from the

technical college system. Ejo-Orusa and Mpi (2019) define electrical craftsmen as trained persons who have acquired sufficient skills in the practice of a trade over long period and in most cases selfemployed. According to Lemon (2018), despite the training enjoyed by electrical craftsmen, they required the technical training on SPS to meet the demands of electrical industry and the needs of the individual. Hence, the technical training can be achieved through the use of selfinstructional guide. A self-instructional guide is a manual designed to contain sequential procedures or instructions for accomplishing various tasks in different areas or aspects of human endeavour (Srivastava, 2019). Salem et al, (2019) further stated that the following should be taken into consideration when designing a self-instructional guide: objectives, content-topics, tasks, procedures, evaluation and facilities required for installation. From the foregoing therefore, Self-instructional guide in the context of this study refers to a compilation of planned contents which specifies; operational tasks, learning objectives for accomplishing identified tasks, tools/materials, and instructional criterion that serve as a guide in teaching the procedures required to carry out installation and maintenance of SPS. The benefits of Self-instructional guide are enormoust the realization of these benefits is hinged on the quality of inputs from the Subject Matter Experts. The Subject Matter Experts (SMEs) are people with special knowledge or skills in a particular of area endeavour (Uduafemhe, 2019). The SMEs are important in development of a selfinstructional guide because, thev determine the steps, related knowledge,

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





attitudes, performance standards, tools and materials needed, and safety concerns required of people performing tasks, for inclusion into the content of the self-instructional guide.

# Statement of the Research Problem

Electrical Installation and Maintenance Works (EIMW) taught in technical colleges are poised with potentials of equipping the students with prerequisite skills to propel them to contribute meaningfully to national economic development, be self-reliant and job creators towards reduction of unemployment. Unfortunately, Ihediwah (2017) stated that, most electrical craftsmen roam the street unhired because they lack saleable skills includes installation which and maintenance of solar power system. The lack of skills among electrical craftsmen on the installation and maintenance of solar power system is simply due to the absence of the contents of Solar Power System in the curriculum used for teaching them. Many solar installations today get bad after short period of installations due to quacks taking over the installations. Therefore, if a self instructional guide for the installation and maintenance of solar power system for electrical craftsmen is developed, it could serve as a basis that will lift them into the competitive market of the industry in which they have a huge stake. The problem of this study is therefore to develop self-instructional guide for installation and maintenance of solar power system for Electrical craftsmen in Nigeria.

# **Research Questions**

1. What are the objectives of selfinstructional guide for installation of solar power system?

2. What are the contents of selfinstructional guide for installation of solar power system?

# Hypotheses

The following hypotheses were tested at 0.05 level of significance:

- H0<sub>1</sub>: There is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and solar private industries on the objectives of self-instructional guide for installation of solar power system.
- H0<sub>2</sub>: There is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and private solar industries on the contents of self-instructional guide for installation of solar

# METHODOLOGY

The study adopted Research and Development (R&D) using Successive Approximation Model (SAM) and quasi experimental research design. Specifically, the Pre-test Post-test nonequivalent Treatment Group Design was employed for the study, in this design, there are two or more groups, but they are not randomly assigned. The groups are compared based on their exposure to different conditions or treatments. The study was carried out in Niger, FCT Abuja, Kaduna and Sokoto States. The population for the study is 235, the

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





population consisted of all the 189 Subject Matter Experts (SMEs) from six solar companies/institutions of learning and 46 electrical craftsmen. Purposive sampling technique (PST) was used for the study, from the population of 189 possible SMEs, purposive sampling technique was therefore used to select 110 SMEs. The instrument for data collection developed by the researcher is titled: Solar Power Systems installation

and maintenance self-instructional guide development questionnaire (SPSIMSIGDQ). Solar Power Systems installation and maintenance selfpsychomotor instructional guide achievement test (SPSIMSIGPAT), Solar Power Systems installation and maintenance self-instructional guide psychomotor rating scale (SPSIMSIGPRS).

The responses scale is stated below:
--------------------------------------

Strongly Agree (SA)/	Highly required,	5
Agree (A)	Required,	4
Disagree (D)	Not Required,	3
Strongly Disagree (SD)	Highly Not Required	2
Undecided (U)	Undecided	1

Source: researcher

The Solar Power Systems installation and maintenance selfinstructional guide psychomotor achievement test (SPSIMSIGPAT) contains five items is a practical question on Solar Power system. The instrument will be a five-point rating scale of Highly Required Strongly Agree/ (SA/HR=5), Agree/Required(A/R=4),Required(D/NR=3), Disagree/Not Strongly Disagree/Highly Not Required (SD/HNR=1) and Undecided (UD=1).

research instruments The SPSIMSIGDO. SPSIMSIGPAT. SPSIMSIGPRS were face and content validated by three experts. The instrument (SPSIMSIGDQ) was pilot tested using 18 SMEs in four solar companies' and. the coefficient of internal consistency of the instrument was calculated using Cronbach's Alpha and found to be: 0.82 and 0.76, for section B and C respectively and overall reliability index of 0.79. The research instruments were administered on the respondents with help of four research assistants, one each from Niger, Sokoto, Kaduna, and FCT Abuja. Data collected from the respondents will be analysed using mean and Analysis of Variance (ANOVA) Mean will be used to analyse data to answer research questions 1-2, ANOVA will be used to test hypothesis 1-2. The choice of mean to answer research questions 1-2 is based on the fact that, it is the commonly used measure of central tendency used in educational reach. The choice of ANOVA to test hypothesis 1-2 is because, it is the most appropriate test to measure the significant difference between the mean scores of three group of respondents above 30 in number. In order to determine the agreement level of the items of the research questions, the mean respondents ratings of will be interpreted using real limits of numbers. Real limits are boundaries located

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





exactly half-way between adjacent categories used to define continuous variables in research (Foster *et al.*, 2018). The real limits of numbers to be used in this study are shown in Table 1.0

#### RESULTS

Analysis and presentation of data are ordered according to the

research questions and hypotheses that guided the study

RQ1: What are the objectives of selfinstructional guide for installation of Solar Power System?

Data for providing answer to this research question 1 are presented in Table.1

Table 3.1: Mean	and Sta	andard	Deviation	of	respondents	on	the	objectives	of	self-
instructional guide for installation of solar power system										

S/NO	ITEM	GIS		G	SL	P	SI	AVE	RAGE	REM
		X	SD	X	SD	X	SD	X	SD	
1	Fundamentals of Electricity	3.83	0.77	4.03	0.85	4.18	0.83	4.01	0.82	Agreed
2	Solar power designs and sizing	4.11	0.85	4.06	0.79	4.09	0.79	4.09	0.81	Agreed
3	Safety precautions	4.17	0.77	3.73	0.84	3.94	0.78	3.95	0.80	Agreed
4	Installation of PV Module	3.97	0.81	4.00	0.87	4.00	0.82	3.99	0.83	Agreed
5	Installation of solar conductor	4.06	0.89	4.03	0.85	4.15	0.89	4.08	0.88	Agreed
6	Installation of charge controller	3.89	0.78	3.85	0.83	3.85	0.82	3.86	0.81	Agreed
7	Installation of inverter	3.83	0.85	3.97	0.85	4.18	0.72	3.99	0.81	Agreed
8	Installation of solar batteries	4.06	0.83	4.21	0.82	4.00	0.78	4.09	0.81	Agreed

The results in Table 3.1 show the mean and standard deviation of the responses of Electrical/Electronic personnel from Government solar industries, Government solar institutions, and Private solar industries on the objectives of self-instructional guide for installation of solar power system. The result of analysis shows that average means of all items of the research question were in the range of 3.86 - 4.09, all of which are in the 3.50 – 4.49 real limit. Therefore, the respondents were in agreement with all the items as the objectives of self-instructional guide for installation of solar power system. Furthermore, the average standard deviations of the items were in 0.80 and 0.88 range. This is an indication that all the responses were dispersed close to the mean. In addition to this, none of the standard deviations was up to the standard normal deviate of

Corresponding author: Sunday A. Alome

<sup>⊠ &</sup>lt;u>sundayalome28@gmail.com</u>

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





1.96. This therefore strengthens the integrity of the mean.

Data for providing answer to this research question 2 are presented in Table 3.2

#### RQ2: What are the Contents of selfinstructional guide for installation of Solar Power System? Table 3 2: Mean and standard deviation

**Table 3.2:** Mean and standard deviation of respondents on contents of self-instructional guide for installation of Solar Power System

S/N	Contents on		IS	G	SL	P	SI	AVE	RAGE	REM
	Fundamentals of	X	SD	X	SD	X	SD	X	SD	
1	Electricity Power (P) is the rate of energy conversion measured in Watts	4.06	0.79	4.12	0.86	3.97	0.76	4.05	0.80	Agreed
2	Voltage (V) is the potential difference in electrical charge between two points measured in Volts	3.83	0.88	4.15	0.71	3.88	0.73	3.95	0.77	Agreed
3	Current (I) is the flow of electrons in a circuit/wire between two points measured in Amperes	3.72	0.74	4.09	0.77	4.15	0.78	3.99	0.76	Agreed
4	When electrical circuits are wired in parallel, currents are added and voltage stays the same.	3.86	0.80	4.15	0.87	4.15	0.70	4.05	0.79	Agreed
5	Power (P) is the rate of energy conversion measured in Watts	4.14	0.90	3.91	0.84	4.21	0.77	4.09	0.84	Agreed
6	Voltage (V) is the potential difference in electrical charge between two points measured in Volts	4.03	0.88	4.00	0.79	4.06	0.85	4.03	0.84	Agreed
7	Current (I) is the flow of electrons in a circuit/wire between two points measured in Amperes	3.83	0.70	4.15	0.83	4.12	0.69	4.03	0.74	Agreed
8	When electrical circuits are wired in parallel, currents are	3.89	0.75	4.24	0.87	4.00	0.78	4.04	0.80	Agreed

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





9	added and voltage stays the same. Resistance (R) is the opposition to the flow	3.89	0.82	3.82	0.73	4.26	0.86	3.99	0.80	Agreed
10	of electrical current in the material through which it is passing measured in Ohms Energy (E) refers to the capacity for work i.e.,	4.03	0.77	4.00	0.87	3.94	0.85	3.99	0.83	Agreed
	the power used over time, measured in Watt hours									
11	In electricity generation there are two distinct types of electrical current - direct current (DC) and alternating current (AC).	3.72	0.85	4.03	0.81	3.85	0.78	3.87	0.81	Agreed
12	Alternating current is the type of current most commonly used in households to power electrical appliances (for example TVs, refrigerators, radios and computers). Grid supplied electricity is alternating current.	4.08	0.81	3.97	0.92	4.09	0.83	4.05	0.85	Agreed
13	Direct current is produced by PV modules and stored in batteries.	3.94	0.79	4.09	0.84	3.94	0.81	3.99	0.81	Agreed
14	Alternating current can be transferred over a long distance	4.17	0.77	4.12	0.78	4.12	0.88	4.14	0.81	Agreed
15	Direct current cannot be transferred over long distance	4.00	0.79	3.94	0.83	3.76	0.82	3.90	0.81	Agreed
16	Alternating current has a frequency of 50Hz or 60Hz	4.03	0.91	4.15	0.76	4.09	0.79	4.09	0.82	Agreed
17	Direct current has zero frequency	3.94	0.86	4.06	0.86	3.68	0.68	3.89	0.80	Agreed

Corresponding author: Sunday A. Alome

Sundayalome28@gmail.com Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





18	Alternating current cannot be stored	3.89	0.92	4.03	0.85	4.06	0.85	3.99	0.87	Agreed
19	Direct current can be stored in batteries	3.92	0.91	3.97	0.85	3.97	0.80	3.95	0.85	Agreed
20	Energy cannot be created nor be destroyed but can be transformed from one form to another e.g. Sunlight to Electricity	3.94	0.79	4.03	0.81	3.85	0.74	3.94	0.78	Agreed

	Contents on Solar Power	G	IS	G	SL	Р	SI	AVE	RAGE	REM
	Designs and Sizing	X	SD	X	SD	X	SD	X	SD	
21	Power = Volts x Current, P = V x I in Watts	4.11	0.85	3.82	0.73	3.82	0.87	3.92	0.82	Agreed
22	Volts= Power /Current, V= P/I in Volts	4.06	0.79	3.76	0.83	3.97	0.90	3.93	0.84	Agreed
23	Current = Power/ Volts, I= P/V in Amperes	4.14	0.87	4.06	0.90	4.24	0.85	4.15	0.87	Agreed
24	Resistance = Volts/ Current, R= V/I in Ohms	3.75	0.84	4.00	0.83	3.91	0.90	3.89	0.86	Agreed
25	Energy = power x time E= P x t in watt-hours	4.11	0.78	4.00	0.94	3.97	0.87	4.03	0.86	Agreed
26	10 watt + 7 watts + 5 watt + 3 watts + 15 watt = 40 watts	3.81	0.79	3.94	0.79	4.12	0.81	3.96	0.80	Agreed
27	A battery of 12V, 200Ah is having a 2400 Watts of Power	3.94	0.89	4.24	0.83	4.21	0.81	4.13	0.84	Agreed
28	Total voltage of four 1.5V DC batteries connected in series is 6 V	4.11	0.75	4.21	0.74	4.00	0.89	4.11	0.79	Agreed
29	Total voltage of four 1.5V DC batteries connected in parallel is 1.5V	4.06	0.83	4.18	0.81	3.94	0.74	4.06	0.79	Agreed
30	Total voltage of three solar panel 120W, 30V connected in series is 90V	3.86	0.83	4.15	0.83	4.00	0.78	4.00	0.81	Agreed
31	Total voltage of three solar panel 120W, 30V each connected in parallel is 30 V	3.92	0.84	3.94	0.79	4.18	0.80	4.01	0.81	Agreed
32	The total amperage of three PV panels in parallel with 32 amps each is 96 A	3.94	0.89	3.79	0.78	3.94	0.85	3.89	0.84	Agreed
33	Total current of three solar panel 120W, 30A connected in series is 30A	4.06	0.79	4.09	0.80	3.88	0.81	4.01	0.80	Agreed

Corresponding author: Sunday A. Alome

⊠ sundayalome28@gmail.com

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





								•		
34	On a clear day, the total	3.75	0.73	3.97	0.81	4.15	0.82	3.96	0.79	Agreed
	insolation striking the earth is									U
	about 1,000 watts per square									
	meter.									
35	A 29-inch colour TV with 120W	4.08	0.84	3.94	0.83	3.91	0.83	3.98	0.83	Agreed
	used for 4hours will need									0
	energy of 280 Watt-Hours									
36	Two Fluorescent Lamps 15W	4.11	0.82	4.15	0.80	3.82	0.83	4.03	0.82	Agreed
	each used for 4 hours will need		0.02	1110	0.00	0.02	0.00	1.00	0.02	ingreed
	energy of 120watt-Hours									
37	PV Module Size = Total Daily	4.06	0.83	4.06	0.83	3.91	0.87	4.01	0.84	Agreed
01	<u>Watt Hours /</u> Average Daily	1.00	0.00	1.00	0.00	0.71	0.07	1.01	0.01	ngreeu
	Solar Insolation									
38	Battery Capacity = <u>Daily Load /</u>	3.78	0.76	3.64	0.78	4.21	0.77	3.88	0.77	Agreed
50	Battery Efficiency	5.70	0.70	5.01	0.70	7,21	0.77	5.00	0.77	ngreeu
39	The size of the inverter will be	3.83	0.81	3.91	0.88	3.94	0.81	3.89	0.83	Agreed
05	given by $246 \times 1.3 = 319.8$ Watts,	5.05	0.01	5.71	0.00	5.74	0.01	5.07	0.05	ngreeu
	the right size of inverter will be									
	400 Watts									
40	Connect PV panels in series and	3.92	0.81	3.94	0.86	3.76	0.78	3.87	0.82	Agreed
10	in parallel	0.72	0.01	0.71	0.00	0.70	0.70	0.07	0.02	ngreeu
41	Ensure safety practices in solar	3.89	0.78	3.88	0.82	3.97	0.80	3.91	0.80	Agreed
11	power installations are obeyed	5.07	0.70	5.00	0.02	5.77	0.00	5.71	0.00	ngreeu
42	Ensure tools and equipment	3.97	0.84	4.00	0.87	3.85	0.86	3.94	0.86	Agreed
14	used in solar power installation	5.77	0.04	4.00	0.07	5.05	0.00	5.74	0.00	ngreeu
	are adequate for the job to be									
	carried out									
43	Ensure the diagnostic tools are	4.00	0.79	3.94	0.83	3.85	0.82	3.93	0.81	Agreed
	functional	1.00	011 2	0101	0.00	0.00	0.01	0.70	0.01	ingreed
44	Ensure proper sizes for the PV	4.33	0.79	4.18	0.88	3.97	0.80	4.16	0.82	Agreed
	panel, charge controller,	1.00	011 2	1110	0.00	0111	0.00	1110	0.02	ingreed
	inverter and battery.									
45	Ensure the right cables sizes for	4.03	0.84	3.94	0.90	3.88	0.88	3.95	0.87	Agreed
	solar power installation									0
46	Ensure the D. C. Circuit	4.03	0.70	4.00	0.97	4.03	0.80	4.02	0.82	Agreed
	breakers are functional									0
47	The total amperage of the four	4.08	0.84	4.03	0.92	3.94	0.78	4.02	0.85	Agreed
	panels connected in series is 3A.									0
	and total current ratings of all									
	panel strings should not exceed									
	80% of the charge controller's									
	current rating (i.e. 24A for the									
	30A charge controller)									
<b>48</b>	Make sure the material is strong	4.11	0.85	4.12	0.89	4.09	0.79	4.11	0.84	Agreed
	enough to provide									Ŭ
	mechanical support to the solar									
	panels and mounting hardware									
	against possible wind load									
	· · ·									

Corresponding author: Sunday A. Alome

⊠ sundayalome28@gmail.com

© 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State.





49	Position the panels to minimize	3.86	0.72	3.97	0.77	4.12	0.77	3.98	0.75	Agreed
	wiring distance between the									0
	solar panel and the charge									
	controller									
50	Batteries contain very corrosive	3.86	0.87	4.24	0.75	4.09	0.87	4.06	0.83	Agreed
	diluted sulfuric acid as									0
	electrolyte. Precautions should									
	be taken to prevent contact with									
	skin, eyes, or Clothing									
51	Check the AC voltage	4.03	0.88	4.06	0.75	4.09	0.87	4.06	0.83	Agreed
	output/input, frequency,									0
	temperature, load cosumption									
	and DC input									
52	Use Multimeter or hygrometer	4.08	0.91	4.03	0.92	3.97	0.87	4.03	0.90	Agreed
	to test the voltage output from									0
	the battery									
53	Connect the positive (+) cable	4.00	0.83	3.76	0.83	4.09	0.87	3.95	0.84	Agreed
	from the battery bank to the									0
	positive terminal of the direct									
	current (battery) side of the									
	inverter. (DC Input). Test that									
	the cable is secure									
54	Install the inverter close to the	3.94	0.75	3.91	0.84	4.00	0.85	3.95	0.81	Agreed
	battery bank									0
55	Pure sine wave power inverter	3.97	0.84	4.21	0.82	4.09	0.71	4.09	0.79	Agreed
	produces cleaner power									
56	These two 12V batteries are	4.25	0.69	4.06	0.83	3.85	0.78	4.05	0.77	Agreed
	paralleled, the amperage is									
	same (that is 12V) but the									
	voltage is doubled									
57	For series connection connect	3.89	0.82	3.88	0.78	4.06	0.89	3.94	0.83	Agreed
	negative (-) to positive (+)									
	terminal									
58	Parallel connection of two	4.11	0.75	3.94	0.83	4.29	0.72	4.11	0.77	Agreed
	number of 12volts batteries									
	Connect the negative terminal									
	(=) negative (=) terminal of the									
	next battery and also positive									
50	(+) to positive (+) terminal.	0.01	0 70	0.01	0.00	0.00	0.00	0.01	0.00	
59	The charge controller should	3.94	0.79	3.91	0.80	3.88	0.88	3.91	0.82	Agreed
	ideally be located in an area									
60	relatively close to the battery	2.07	0.00	1 10	0.00	2.04	0.70	2 00	0.70	1 1
60	The "100 watts" rating on the	3.86	0.90	4.18	0.68	3.94	0.78	3.99	0.79	Agreed
	solar panel isn't extremely									
	useful, unless you know that it's									
61	100 watts at 12V	2.00	0.79	4.00	0 77	1.00	0.70	1 01	0.75	ل مسمع ما
61	Two or more solar panels	3.89	0.78	4.09	0.77	4.06	0.69	4.01	0.75	Agreed
	connected in parallel to increase									
	the current output while the									





	enterest explored monophing the	-									
	output voltage remains the same.	e									
62	Two or more batterie		0.	81 4	.18	0.73	3.97	0.80	4.06	0.78	Agreed
	connected in parallel to increase the current output while the										
	output voltage remains the										
	same.										
63	Only use properly insulated		0.	83 3	.76	0.75	3.97	0.80	3.91	0.79	Agreed
	tools when making batter	Ý									
64	Do not over use the battery	y 3.81	0.	79 3	.88	0.86	4.00	0.85	3.90	0.83	Agreed
	while at low voltage else it wil										0
65	die quick	6 4 1 0		75 4	10	0.02	2 00	0.94	1.00	0.80	A succed
65	Check the general condition o the array module wiring and		0.	75 4	.12	0.82	3.88	0.84	4.06	0.80	Agreed
	mounting hardware bi										
	annually										
66	Always use the correct tool during maintenance operation		0.	73 4	.06	0.86	4.06	0.81	4.01	0.80	Agreed
	to avoid damaging the sola										
	panel										
67	Replace any broken or cracked		0.	81 3	.85	0.80	3.88	0.77	3.92	0.79	Agreed
	panel to ensure full system functionality	n									
68	Make sure inverter rating	s 4.03	0.	82 3	.88	0.81	3.92	0.78	3.94	0.80	Agreed
	exceed total system wattage by	y									0
	20%										
	Contents on Safety	GIS		GSL		PSI		AVI	ERAGE	E REM	1
	Precautions	x	SD	x	SD	x	SD	x	SD		
69	Understand the	4.11	0.89	4.12	0.74	4.00	0.74	4.08	0.79	Agre	eed
	components to be install									0	
	or maintained before										
	starting the process of installation or										
	maintenance.										
70	Wear Safety goggles	4.11	0.85	3.97	0.88	4.21	0.84	4.10	0.86	Agre	eed
	when installing a solar battery										
71	Wear Safety hard hats,	4.00	0.86	4.30	0.81	3.82	0.83	4.04	0.83	Agre	eed
	when installing a solar PV									0	
70	Module	4.1.4	0.00	0.01	0.04	0.01	0.00	2.00	0.00		1
72	Wear Safety protective gloves carrying out	4.14	0.83	3.91	0.84	3.91	0.83	3.99	0.83	Agre	eed
	installation on solar										
	instantion on solar										
	power system.										
73		3.89	0.85	4.03	0.85	4.32	0.77	4.08	0.82	Agre	eed

Corresponding author: Sunday A. Alome

Ξ

Sundayalome28@gmail.com Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





-										
	installing a Solar power									
74	system	2 02	0.01	4.15	0.97	4 1 2	0 77	4.02	0.02	A
74	Wear Safety clothing, non-slip boots, when	3.83	0.81	4.15	0.87	4.12	0.77	4.03	0.82	Agreed
	installing a solar power									
	system									
75	Wear Safety respiratory	4.00	0.83	3.82	0.77	4.12	0.88	3.98	0.83	Agreed
	protection. It is important									0
	to wear the appropriate									
	safety gear while working									
	with solar power systems									
	to avoid potential injury									
76	or harm. Secure the Roof: Make	4.06	0.62	4.09	0.05	2.05	0.02	1.00	0.00	Agreed
76	sure the roof is	4.06	0.63	4.09	0.95	3.85	0.82	4.00	0.80	Agreed
	structurally sound and									
	secure. If it is necessary to									
	walk on the roof, use									
	safety precautions such as									
	using a safety harness and									
	non-slip shoes	2.04	0.70	0.01	0.70	4.00	0.07	2.04	0.70	
77	Choose the Right	3.94	0.79	3.91	0.72	4.03	0.87	3.96	0.79	Agreed
	Equipment: Choose components that are									
	certified and designed for									
	solar installation									
78	Install Properly: Install	4.22	0.87	3.94	0.79	3.91	0.79	4.02	0.82	Agreed
	components according to									0
	manufacturer's									
	instructions, using the									
	appropriate tools and fasteners.									
79	Properly Ground System:	4.11	0.92	3.88	0 74	3 76	0.82	3.92	0.83	Agreed
.,	Ground the system to	1.11	0.72	0.00	0.7 1	0.70	0.02	0.72	0.00	rigieea
	meet local electrical codes.									
80	Protect the Inverter:	4.11	0.78	4.06	0.90	4.00	0.89	4.06	0.86	Agreed
	Install the inverter in an									
	area protected from									
	weather and direct									
81	sunlight Monitor System	3 72	0.74	3 67	0.69	4.03	0.87	3 81	0.77	Agreed
01	Performance:	5.72	0.74	5.07	0.07	4.05	0.07	5.01	0.77	ngieeu
82	Install the charge	3.78	0.76	4.03	0.81	3.88	0.84	3.90	0.80	Agreed
	controller far from any	-								0
	inflammable substance									
83	Install the battery far from	4.06	0.83	4.03	0.81	3.85	0.82	3.98	0.82	Agreed
	any inflammable									
	substance									

Corresponding author: Sunday A. Alome

Sundayalome28@gmail.com Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





84	Maintain th	e System:	3.81	0.82	4.09	0.80	4.03	0.87	3.98	0.83	Agreed
	Perform	routine									0
	maintenance,	such as									
	cleaning solar	panels and									
	replacing ba										
	keep the system										
	safely and effi	ciently.									

	Contents on Installation of PV	GI	S	G	SL	Р	SI	AVE	RAGE	REM
	Module	x	SD	x	SD	x	SD	x	SD	
85	Select the right tool for the job	3.97	0.77	4.00	0.79	3.97	0.87	3.98	0.81	Agreed
86	Position your scaffold or ladder properly on the wall.	4.00	0.79	3.97	0.88	4.29	0.76	4.09	0.81	Agreed
87	Climb the ladder to the roof or the rack where panels will be mounted	4.06	0.86	4.21	0.89	4.06	0.85	4.11	0.87	Agreed
88	Determine the right location for the installation.	3.97	.81	4.03	.81	4.09	.87	4.03	0.83	Agreed
89	Take measurement and compare with the size of panels to be mounted		0.81	4.03	0.85	3.82	0.87	3.96	0.84	Agreed
90	Mount fasteners and brackets.	4.14	0.80	4.12	0.89	4.32	0.81	4.19	0.83	Agreed
91	Two or more people should carry the panel gently and gradually to the top of roof	3.94	0.86	4.18	0.77	3.97	0.80	4.03	0.81	Agreed
92	Attach Solar Panel - Secure the solar panel to the mounting system with the appropriate hardware	4.31	0.82	4.00	0.87	4.24	0.89	4.18	0.86	Agreed
93	Connect Wiring - Connect the wiring on the solar panels	4.03	0.77	3.91	0.80	4.00	0.89	3.98	0.82	Agreed
94	Connect the wiring from the solar panel to the central conductor.	4.06	0.86	3.88	0.89	4.06	0.81	4.00	0.85	Agreed
95	Test and Inspect - Test the system and inspect all panels to ensure that the installation has been completed correctly	3.89	0.85	3.97	0.77	3.76	0.82	3.87	0.81	Agreed

	Contents on Installation of	C	GIS	C	SSL	I	PSI	AVE	RAGE	REM
	Solar Conductor —	X	SD	X	SD	X	SD	X	SD	
96	Plan the solar conductor system:3. Determine the size of the system	94	0.86	4.03	0.88	4.00	0.89	3.99	0.88	Agreed

Corresponding author: Sunday A. Alome

Sundayalome28@gmail.com Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State.





needed, the location of the system, and any other requirements. 97 Obtain permits and approval: 4.11 0.85 3.97 0.88 4.000.78 4.03 0.84 Agreed Secure all necessary permits, such as electrical and building permits, and approval from local authorities or utility companies. 98 Prepare the installation site: 4.11 0.82 4.30 3.82 0.78 Agreed 0.81 0.72 4.08Clear the area if necessary, and necessary make any modifications to the structure 99 Install the mounting structure: 4.06 0.89 3.94 0.81 4.27 0.72 0.81 4.09 Agreed Construct the mounting structure or frame to support the solar conductors 100 Install the solar conductors: 4.17 0.813.91 0.88 4.03 0.87 4.040.85 Agreed Connect the solar conductors to the mounting structure and adjust the angles the of conductors for maximum exposure to the sun. 101 Connect the system to the 4.11 0.82 3.76 0.83 4.18 0.76 4.02 0.80 Agreed electrical system: Connect the solar conductors to the electrical system, including any necessary wiring, breakers, and control equipment. 102 Test the system: Perform a 3.83 Agreed 0.85 4.000.83 3.91 0.83 3.91 0.84thorough test of the solar conductor system to ensure proper operation 103 Monitor the system: Monitor the 4.00 0.89 0.85 4.21 0.82 3.82 0.83 4.01Agreed system regularly to ensure it is operating correctly and making the most of available solar energy. **Contents on Installation of Charge** GIS GSL PSI AVERAGE REM Controller Х SD SD X SD X SD Х 104 Install the Solar Charge Controller: 3.89 0.92 3.97 0.85 0.82 4.00 4.15 0.86 Agreed Begin by opening the solar charge controller's box and taking out the contents. Make sure that all the necessary components are included in the box. Place the solar charge controller in an area that has easy

Corresponding author: Sunday A. Alome

⊠ sundayalome28@gmail.com

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State.

© 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





access to both the photovoltaic (PV) array and the battery bank 105 Connect the Photovoltaic Array: Use 3.89 0.75 3.70 0.77 3.97 0.72 3.85 0.75 Agreed an appropriate cable to connect the photovoltaic array to the solar charge controller's PV input terminals. Make sure that the cables used to connect the array is rated for the intended current and voltage 106 Connect the Battery Bank: Connect 3.89 0.82 4.21 0.82 4.15 0.82 4.080.82 Agreed the battery bank to the solar charge controller's battery output terminals using an appropriate cable. Make sure that the cables used to connect the battery bank are rated for the intended current and voltage. 107 Connect the Load: Connect the load 0.81 4.27 0.84 4.06 0.78 4.17 4.170.81Agreed to the solar charge controller's load terminals using an appropriate cable. Make sure that the cables used to connect the load are rated for the intended current and voltage 108 Test the System: Turn on the system 4.080.844.000.87 3.97 0.76 4.02 0.82 Agreed and test for proper operation. Make sure that the load is receiving power from the battery bank and that the battery bank is being charged 109 Try to read the battery voltage on the 3.92 0.73 3.97 0.88 4.12 0.77 4.00 0.79 Agreed screen of the charge controller to be okay 110 Make sure the indicator lights are 3.75 0.84 3.97 0.81 4.000.82 3.91 0.82 Agreed showing properly 111 Connect the battery to the charge 4.03 0.813.88 0.86 4.03 0.83 3.98 0.83 Agreed controller

	Contents on Installation of Solar	GIS GS		SL PSI		AVERAGE		REM		
	Inverter		SD	X	SD	X	SD	X	SD	
112	Clean the Inverter.	4.06	0.79	3.70	0.81	3.79	0.73	3.85	0.78	Agreed
113	Check the Fuses and Circuit Breakers:	4.11	0.85	3.94	0.79	3.91	0.83	3.99	0.82	Agreed
114	Check the Connections: Make sure all the connections are securely connected and all screws are tightened.	4.00	0.83	4.06	0.83	4.03	0.72	4.03	0.79	Agreed

Corresponding author: Sunday A. Alome

⊠ <u>sundayalome28@gmail.com</u>

© 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State.





115	Inspect the Wiring: Check for any signs of fraying or corrosion on the wiring and replace any damaged wires.	3.86	0.83	4.06	0.75	4.00	0.82	3.97	0.80	Agreed
116	Test the Inverter: Turn on the inverter and test it to make sure it is	4.08	0.77	4.03	0.95	3.97	0.76	4.03	0.83	Agreed
117	working properly. Check the Temperature: Make sure	3.97	0.77	3.97	0.77	3.65	0.69	3.86	0.74	Agreed
118	the inverter is not getting too hot. Check the Control Panel: Make sure all the settings are correct and	3.97	0.81	4.06	0.79	4.18	0.80	4.07	0.80	Agreed
119	functioning properly. Run a Diagnostic Test: Run a diagnostic test to make sure the inverter is working correctly.	4.03	0.81	4.00	0.83	4.09	0.90	4.04	0.85	Agreed
	Contents on Installation of Solar	G	IS	G	SL	Р	SI	AVER	RAGE	REM
	Battery	x	SD	x	SD	x	SD	x	SD	
120	Purchase the right solar batteries based on your needs. Consider the number of batteries you need and the type of battery that works best	3.92	0.84	4.15	0.71	4.06	0.74	4.04	0.76	Agreed
121	for your application. Connect all the batteries together to form a series, so that they are able to store the same amount of charge. This is done by connecting the positive terminal of one battery to the negative terminal of the next battery in the series	4.00	0.83	3.76	0.79	4.09	0.87	3.95	0.83	Agreed
122	Connect the solar panel to the solar battery. Ensure that the voltage of the solar panel is the same as the voltage of the solar battery, otherwise the battery will not be able to charge properly.	4.03	0.77	3.88	0.78	4.12	0.77	4.01	0.77	Agreed
123	Mount the solar panel and the solar battery on a secure surface. Make sure that the solar panel is facing the sun and that the solar battery is in a well-ventilated area, as heat can	3.97	0.81	4.09	0.80	3.82	0.83	3.96	0.81	Agreed
124	affect the performance of the battery. Connect the solar panel to the solar battery using the proper wiring. Make sure to connect the positive terminal of the solar panel to the	4.11	0.89	3.85	0.80	3.85	0.74	3.94	0.81	Agreed

Corresponding author: Sunday A. Alome

Sundayalome28@gmail.com Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





	positive terminal of the solar battery and the negative terminal of the solar panel to the negative terminal of the solar battery.									
125	Ensure that the solar controller is	4.08	0.81	3.94	0.79	4.15	0.82	4.06	0.81	Agreed
	connected properly to the solar panel									Ū.
	and solar battery. This will ensure									
	that the solar battery is not									
	overcharged.									
126	Connect the inverter to the solar	3.97	0.81	4.21	0.78	4.06	0.89	4.08	0.83	Agreed
	battery. This will allow you to use									
	the electricity stored in the solar									
405	battery for different appliances.	0.00	0.74	4.45	0.51	0.01	0.00	2.04	0 74	
127	Test the installation to make sure	3.83	0.74	4.15	0.71	3.91	0.83	3.96	0.76	Agreed
	that everything is working properly									
	and that the solar battery is charging									
	correctly									

The results In Table 3.2 show the mean and standard deviation of the responses of Electrical/Electronic personnel from Government solar industries, Government solar institutions, and private solar industries on the objectives of self-instructional guide for installation of solar power system. The result of analysis shows that average means of all items of the research question in all the tables were in the range of 3.81 - 4.18 all of which are in the 3.50 - 4.49 real limit. Therefore, the respondents were in agreement with all the items as the Contents of self-instructional guide for installation of Solar Power System. Furthermore, the average standard deviations of the items were in 0.74 and 0.88 range. This is an indication that all the responses were dispersed close to the mean. In addition to this, none of the standard deviations was up to the standard normal deviate of 1.96. This therefore strengthens the integrity of the mean.

# **Hypothesis 1**

**H0**<sub>1</sub>: There is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and solar private industries on the objectives of self-instructional guide for installation of solar power system.

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





**Table 3.3:** Summary of Analysis of Variance (ANOVA) in responses to Electrical/ Electronics personnel from government solar industries, Government solar institutions of learning and solar private industries on the objectives of self-instructional guide for installation of solar power system.

	Sum of Squares	df	Mean	F	Sig.
			Square		
Between Groups	0.084	2	0.042	0.470	0.627
Within Groups	8.911	100	0.089		
Total	8.995	102			

The results of Analysis of Variance (ANOVA) for the research hypothesis (H0<sub>1</sub>) show that there is no significant difference among the mean of Electrical/Electronics responses from Government personnel solar industries, Government solar institutions of learning and solar private industries on the objectives of self-instructional guide for installation of solar power system. The value of F (0.470) is less than the critical value of F (3.84) and the significance level (0.627) is greater than the level of significance (0.05). This suggests that the null hypothesis  $(H0_1)$ can be accepted. In other words, there is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and solar private industries on the objectives of self-instructional guide for installation of solar power system.

# **Hypothesis 2**

H0<sub>2</sub>: There is no significant difference responses among the mean of Electrical/Electronics personnel from Government solar industries and institutions, and private solar industries on the contents of self-instructional guide for installation of solar power system.

**Table 3.4:** Summary of Analysis of Variance (ANOVA) in responses to Electrical/ Electronics personnel from government solar industries, Government solar institutions of learning and solar private industries on the contents of self-instructional guide for installation of solar power system

<b></b>	Sum of	df	Mean	F	Sig.
	Squares		Square		
Between Groups	0.009	2	0.005	1.129	0.328
Within Groups	0.416	100	0.004		
Total	0.425	102			

The results of Analysis of Variance (ANOVA) for the research hypothesis (H0<sub>2</sub>) show that there is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries, Government solar institutions of learning and solar private industries on the contents of self-instructional guide for installation of solar power system. The results indicate that there is no significant difference among the mean

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





responses of the two groups on the contents of the self-instructional guide. This is evidenced by the low F-value of 1.129 and the high Sig. value of 0.328. These results support the hypothesis (H0<sub>2</sub>) that there is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and private solar industries on the contents of self-instructional guide for installation of solar power system. In conclusion, the results of this t-test analysis support the hypothesis (H0<sub>2</sub>) that there is no significant difference among the mean responses of Electrical/Electronics personnel from Government solar industries and institutions, and private solar industries on the contents of self-instructional guide for installation of solar power system.

#### **DISCUSSION OF FINDINGS**

The findings on objectives of self-instructional guide for installation of Solar Power System revealed that all the 8 items were agreed on by respondents as objectives of self-instructional guide for installation of Solar Power System, their mean ranges from 3.86 -4.09. There wass no significant difference among the responses mean of Electrical/Electronics personnel from Government solar industries, solar Government institutions of learning and solar private industries on the objectives of self-instructional guide for installation of solar power system

The findings on contents on for installation of Solar Power System revealed that all the 127 items were agreed on by respondents as the contents on fundamentals of electricity for installation of solar power system with mean ranges from 3.50- 4.18. the items include Power (P) is the rate of energy conversion measured in Watts, Voltage (V) is the potential difference in electrical charge between two points measured in Volts, Current (I) is the flow of electrons in a circuit/wire between two points measured in Amperes, Power (P) is the rate of energy conversion measured in Watts, Voltage (V) is the potential difference in electrical charge between two points measured in Volts, When electrical circuits are wired in parallel, currents are added and voltage stays the same, Energy (E) refers to the capacity for work i.e., the power used over time, measured in Watt hours, Alternating current is the type of current most commonly used in households to power electrical appliances (for example TVs, refrigerators, radios and computers). Grid supplied electricity is alternating current (AC)and direct current (DC) is produced by PV modules and stored in batteries, among others.

In the same vein, analysis of hypothesis two revealed that there was no significant difference between the mean responses of Electrical/Electronics personnel from solar Government industries. Government solar institutions of learning and solar private industries on the, contents of installation of solar power system.

# CONCLUSION RECOMENDATIONS

AND

Government policies maker in Tambari, and Kelechi (2022) expects electrical craftsmen in Nigeria to possess the skills and knowledge necessary to safely install, repair, and maintain

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





electrical systems and equipment. They must be able to read and interpret electrical diagrams and schematics, and be able to troubleshoot and repair electrical systems. Craftsmen must be knowledgeable in the use of tools and safety procedures, and be able to work efficiently and accurately. Government policies makers should lay more emphasis on curriculum review as when due to introduce new trades like solar power system installation in order to address the technological advancement across all trades in the technical colleges in Nigeria. The findings of this study have a positive implication for electrical company craftsmen, supervisors, Lecturers in Electrical Engineering Technology, curriculum developers, individuals interested in independent power system, National Energy Commission, Commissions in charge of rural and urban streetlight development and maintenance should adopt the selfinstructional guide.

# REFERENCES

Dahuwa, D., Bello, I., & Ibrahim, A. (2017). Solar power technology (SPT) as an alternative to power generation. Journal of Emerging Trends in Engineering and Applied Sciences, 8(4), 160-165.

Ejo-Orusa, H., & Mpi, D. L. (2019). Reinventing the 'Nwaboi 'apprenticeship system: A platform for entrepreneurship promotion in Nigeria. International Journal of Advanced Research in Management and Social Sciences, 8(9), 98-130.
Ihediwah, O. E. (2017). Measures for

effective maintenance of introductory technology equipment in junior secondary

schools in abia state. An Unpublished M.Ed Project Submitted to the Department of Vocational Teacher Education, University of Nigeria, Nsukka. Messenger, R. (2017). Photovoltaic systems engineering. CRC press. Mughees, M., Sadaf, M., Khan, S., Rasheed, A., Daniel, K., & Gelani, H. E. (2020, October). Impact of Shading, Dust Accumulation and Temperature rise on the Performance of Solar PV: The Case of Pakistan. In 2020 International Symposium on Recent Advances in Electrical Engineering & Computer Sciences (RAEE & CS) (Vol. 5, pp. 1-6). IEEE.

- Mutezo, G., and Mulopo, J. (2021). "A review of Africa's transition from fossil fuels to renewable energy using circular economy principles." *Renewable and Sustainable Energy Reviews* 137 (2021): 110609.
- Salem, K. N., & Omar, S. H. (2019). Assessing the Performance of Secondary School Students' in Learning Reading Comprehension Communicatively. *Journal Of Al-Frahedis Arts*, 1(27), 52-71.
- Srivastava, A. K. (2019). Perspective of Teacher Education and Curriculum Studies (Vol. 1). Booksclinic Publishing.
- .Tambari, M. D., & Kelechi, C. (2022). Assessing Skills Required in Maintenance and Repairs of Electric Motors for Self-Reliance in Post Covid-19 Era Among Electrical/Electronic Students in Rivers State Technical Colleges. Vocational and Technology Education

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved





Uduafemhe E. M. (2019) Development and Validation of Additional Cognitive and Psychomotor Skills Contents for Satellite Transmission and Reception Module for Technical Colleges in Nigeria. *An Unpublished PhD Thesis* presented to the Department of industrial and technology Education, Federal University of Technology Minna, Niger state, Nigeria. Ukandu, O. (2016). Development of Self-Instructional Manual for Installation, Operation and Maintenance of Solar Panel Technology for National Diploma Graduates (Unpublished Zhang, M., Huang, S., Li, P., Shah, K. W., & Zhang, X. (2021). Application of dehumidification as anticorrosion technology on

suspension bridges: A review. *Applied Thermal Engineering*, 117549.

Corresponding author: Sunday A. Alome

Industrial and Technology Education Department, Federal University of Technology, Minna, Niger State. © 2023. Faculty of Tech. Education, ATBU Bauchi. All rights reserved